



www.micro-blaze.com  
 800-626-6598  
 713-691-6468

## Micro-Blaze Out® Plus

### Spring 2001 Foam Test

3% Premix – Type III – 93 Octane Gas – 0.06 gpm / sq ft Application Rate

Test #	Concentrate	Control [min:sec]	Extngshmnt [min : sec]	First Torch*	Second Torch**	10 sq ft Burnback Test	
						Area [sq ft]	Notes
16	Verde Environmental, Inc.: Micro-Blaze Out Plus® 3% AFFF Lot # 010119	1:43	2:33	NO IGNITION	NO IGNITION	Self- Extngshmnt	Walkover 14:00 – 14:55.  Self-extngshmnt at 14:55.

**Notes:**

- \*: First torch was conducted between 4:30 and 5:30 for all tests.
- \*\* : Second torch was conducted between 11:00 and 11:50 for all tests.

